

CORRIGENDUM - II

for

Tender Notification No.: 24SP021T dated: 16.04.2024

Notice Inviting Tender for the Supply and Fixing of UPVC Windows (Fifth and Sixth Floor) at Chennai Campus of IIM Tiruchirappalli.

Corrigendum/Amendments in the tender document

1. Please refer to the above-mentioned tender document the Supply and Fixing of UPVC Windows (Fifth and Sixth Floor) at Chennai Campus of IIM Tiruchirappalli.
2. The following changes have been made in the Tender Document through this corrigendum – II

S. No	Reference to the Tender	Queries raised by the Bidders	Clarification from IIMT
1		Whether the removal of the existing Aluminium Sliding Windows under the Vendor/Institute?	The existing window removal work is covered under the scope of the Civil Vendor.
2		Finishing around the window	It is the scope of the UPVC Window Fabricator to properly finish the all-around wall and take final measurements at the site before taking up the fabrication work of the window. After fixing the gap between the wall and the window frame, it should be sealed with silicon without an air gap to ensure soundproofing.
3		Request for the inclusion of additional brands.	No. Brands mentioned in the tender are final and binding.
4	A measurement book should be maintained to record site measurements at the site and the same should be countersigned by the Engineer i/c for passing the bill.		
5	For any clarifications arise during execution, decision of Engineer i/c will be final and binding.		
6	It is once again reiterated that, the <i>Revised Annexure – II (Price Bid – BoQ)</i> is incorporated from Page 2 of the <i>Corrigendum – I</i> . Hence the bidder should quote their rate only in the Revised Price Bid as available in the <i>Corrigendum – I</i> and the same has to be placed in Price Bid Cover(i.e. Cover 2).		

All other points mentioned in the Tender document, Corrigendum – I and other than the above Corrigendum will remain the same.